

# TOWN OF NEW MILFORD

“Gateway to Litchfield County”

Office of the Fire Marshal

---

## Testing and Maintenance.

### 1. Fire Alarm System NFPA 72 **YEARLY OR AS REQUIRED BY SYSTEM**

7-6.1.4 A fire alarm system required for life safety shall be installed, tested, and maintained in accordance with applicable requirements of NFPA 70, National Electrical Code, and NFPA 72, National Fire Alarm Code.

### 2. Fire Extinguishers NFPA 10 **MONTHLY AND YEARLY**

7-7.4 Manual Extinguishing Equipment.

7-7.4.1\* Where required by the provisions of another section of this Code, portable fire extinguishers shall be installed, inspected, and maintained in accordance with NFPA 10, Standard for Portable Fire Extinguishers.

### 3. Emergency lighting NFPA 101 **MONTHLY AND YEARLY**

5-9.3 Periodic Testing of Emergency Lighting Equipment.

A functional test shall be conducted on every required battery-powered emergency lighting system at 30-day intervals for a minimum of 30 sec. An annual test shall be conducted for a 1 1/2-hr duration. Equipment shall be fully operational for the duration of the test. Written records of visual inspections and tests shall be kept by the owner for inspection by the authority having jurisdiction.

### 4. Emergency Generator NFPA 110

5-9.2.3 Emergency generators providing power to emergency lighting systems shall be installed, tested, and maintained in accordance with NFPA 110, Standard for Emergency and Standby Power Systems. Stored electrical energy systems where required in this Code shall be installed and tested in accordance with NFPA 111, Standard on Stored Electrical Energy Emergency and Standby Power Systems.

7-1.3 Emergency generators, where required for compliance with this Code, shall be tested and maintained in accordance with NFPA 110, Standard for Emergency and Standby Power Systems.

### 5. Egress NFPA 101

5-10.5 Testing and Maintenance.

5-10.5.1 Exit signs shall be visually inspected at maximum 30-day intervals for operation of the illumination sources.

# TOWN OF NEW MILFORD

“Gateway to Litchfield County”

Office of the Fire Marshal

---

5-10.5.2 Exit signs connected to or provided with a battery-operated emergency illumination source, where required in 5-10.3.5, shall be tested and maintained in accordance with 5-9.3.

## 6. Sprinkler System NFPA13

### 7-7.5\* Maintenance and Testing.

All automatic sprinkler and standpipe systems required by this Code shall be inspected, tested, and maintained in accordance with NFPA 25, Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems.

## 8. Fire Pumps NFPA 25

### 7-7.5\* Maintenance and Testing.

All automatic sprinkler and standpipe systems required by this Code shall be inspected, tested, and maintained in accordance with NFPA 25, Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems.

## 9. Hood Systems NFPA 96

Commercial cooking equipment shall be installed in accordance with NFPA 96, Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations.

## 10. Elevator

### 7-4.8 Elevator Testing.

Elevators shall be subject to routine and periodic inspections and tests as specified in ASME/ANSI A17.1, Safety Code for Elevators and Escalators. All elevators equipped with fire fighter service in accordance with 7-4.4 and 7-4.5 shall be subject to a monthly operation with a written record of the findings made and kept on the premises as required by ASME/ANSI A17.1, Safety Code for Elevators and Escalators.